



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 7/17/09

Code 50.10.4-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R602.10.5.4 Continuously sheathed braced wall lines		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>R602.10.5.4 Continuously sheathed braced wall lines. Where a, Method CS-SFB, continuously-sheathed <i>braced wall line</i> is used in Seismic Design Categories D₀, D₁ and D₂ or regions where the basic wind speed exceeds 100 miles per hour (45 m/s), the <i>braced wall line</i> shall be designed in accordance with accepted engineering practice and the provisions of the International Building Code <u>Indiana Building Code</u>. Also, all other exterior <i>braced wall lines</i> in the same <i>story</i> shall be continuously sheathed.</p>		
REASON AND FISCAL IMPACT		
<p>Method CS-SFB is added to the first line to ensure that other methods of wall bracing are not incorrectly applied to this section. The reference to the IBC is changed to the InBC.</p> <p>Fiscal impact: there is no increase to the cost of construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		